OVE Austrian Electrotechnical Association

Eschenbachgasse 9 | 1010 Wien | Austria

ZVR: 327279890 | www.ove.at

OVE Testing and Certification

Kahlenberger Str. 2A | 1190 Wien | Austria T +43 1 370 58 06 | certification@ove.at

ENEC Certification Body registered under ID # 11.



Validity of ENEC Licences can be checked at www.enec.com

LICENCE

to use the European Mark



Licence No.: 251-197 Date of issue: Wien, 2018 10 24 Wien, 2020 10 16 Rev. No.: 02

OVE the Austrian Electrotechnical Association as signatory to the "Agreement on the use of a commonly agreed Mark of Conformity for certain electrical equipment complying with European Standards" hereby grants the right to label the products mentioned hereunder and listed in the Annex with the Mark(s) shown above to the following company

Licenceholder: **Zumtobel Lighting GmbH**

> Schweizer Str. 30 6850 Dornbirn

Austria

Product: Luminaires for emergency lighting with limited surface temperatures

Trade Mark: **THORN**

Series/Type: **Aquaforce Pro**

Basis for this given right is the conformity of the products with the requirements of the relevant Standard(s) as listed in the Annex and the fulfilment of articles 8 and 9 of the ENEC-Agreement by the manufacturer. This licence refers to the tested specimen and to all products manufactured strictly identical to the submitted one.

This licence has been issued under the presumption and conditional on the fact that the licensee holds all necessary legal rights with regard to the product presented for testing and certification.

Österreichischer Verband für Elektrotechnik

Head of Testing and Certification

Digitally signed by W. Martin Email=w.martin@ove.at

Dipl.-Ing. W. Martin



OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.





Date: 2020 10 16 Page 2 of 5

Hersteller **Thorn Lighting Ltd** Durhamgate, Spennymoor, Manufacturer County Durham **DL16 6HL United Kingdom** Fertigungsstätte(n) **Zumtobel Lighting GmbH** Factory location(s) Schweizer Str. 30 6850 Dornbirn Austria Typenbezeichnung Series AQFPRO . LED..., Type reference see page 5 Prüfbericht TR-251-0114-01 ECS, Test Report TR-251-0114-02 ECS, TR-251-0114-03 ECS OVE EN 60598-1:2018-11-01 Nationale Bestimmung(en) National Standard(s) ÖVE/ÖNORM EN 60598-2-22:2015-07-01 ÖVE/ÖNORM EN 60598-2-24:2014-05-01 Europanorm(en) EN 60598-1:2015 + A1:2018 European Standard(s) EN 60598-2-22:2014 EN 60598-2-24:2013 Ersatz für Zertifikat 251-197 Rev. 01 dated 2020 09 01 Items modified are marked with an asterisk (*) Superseded licence Anmerkung(en) All types available as centrally supplied maintained Remark(s) emergency luminaire (classification Z 1), according EN 60598-2-22:2014. Only types with lumen packages 2900lm, 4300lm and 6400lm are also available as self contained emergency luminaire (classification X 1), according EN 60598-2-22:2014. CTF Stage 2





Date: 2020 10 16

Page 3 of 5

Nennspannung Rated voltage 220-240 V; 0/50/60 Hz

Anzahl und Leistung der Lampen Rated wattage and number of lamps

2/3 x LEM S40...

Lampentyp(en)
Lamp identification

LED modules (ILCOS: DSL)

Schutzgrad

Degree of protection

IP66

Netzanschluss

Screwless terminals

Supply connection

Befestigungsfläche Supporting surface Normally flammable surface

Schutzklasse Class of protection

CI. I

Beschreibung des Aufbaus Description of construction

Emergency luminaires with limited surface temperatures for wall and ceiling mounting. The luminaire has a special drip-edge-effect. Two different optics, Middle Beam or Wide Beam are available. The LED modules and the ECG are fixed on the light engine

with screws.

Zusatzinformation Additional information Light source classified as RG0 according to

EN 62471:2008.





Date: 2020 10 16 Page 4 of 5

Bauteil Component		Hersteller Manufacturer	Typenbezeichnung Type Reference	Konformitätszeichen Mark(s) of conformity
LED module	A *	Zumtobel	LEM \$40	ÖVE
LED control gear	B B B B B B B B B B B B B B B B B B B	Tridonic Tridonic Thorn Thorn Tridonic Tridonic Tridonic Tridonic Tridonic Philips Philips Philips Osram Osram Osram Osram Tridonic Tridonic Tridonic	LCA 50W LCA 75W LC 35W LC 54W LC 35W LC 54W LC 54W LC 67W LCAI 100W Xitanium 36W Xitanium 60W Xitanium 75W OTi 35 OTi 60 OTi 75 OTi 90 EM converterLED BASIC EM converterLED PRO	ENEC 11 ENEC 18 ENEC 18 ENEC 18 ENEC 18 ENEC 11 ENEC 11 ENEC 11 ENEC 11 ENEC 05 ENEC 05 ENEC 05 VDE VDE VDE VDE VDE ENEC 12 ENEC 12
Sensor	Α	Tridonic	smartSWITCH HF; 220-240V; 50Hz; Tc 70°C	ENEC 05
Terminal	Α	Electro Terminal	SLK 3; ACDC 450 V; 24A; 0,5-2,5 mm²; T110	ENEC 11
Connector	Α	Stucchi	3701, 3702; 400V; 16A; T110	IMQ
Wiring	Α	Leoni	Ecosense S05G-U;	ввЈ
	Α	Leoni	300/500 V; 0,5 mm²; 110°C Ecosense S07G-U; 450/750 V; 1,5 / 2,5 mm²; 110°C	ВВЈ
Battery	Α	GP	400LALHT; 40000mAh; T=50°C; U _{Zelle} =1,2V	CB (DK-98228-UL)
Enclosure	С	Zumtobel	PMMA, PC	checked within appliance

- Α The component is replaceable with another one, also certified, with equivalent characteristics.
- A* B C The component is replaceable with another one according to ETF5-OSM-LUM/DSH 2057.
- The component is replaceable if authorised by the test house.
- Integrated component tested together with the appliance.
- D Alternative component.








Date: 2020 10 16 Page 5 of 5

Typecode:



Accessories: AQFPRO FIX/CH KIT

AQFPRO MCA KIT

MOUNTING SET AQUAFORCE PRO DIFUSER AQUAFORCE PRO * * **

HLD TW AQFPRO

HOUSING AQUAFORCE PRO*

OVE Testing and Certification

